



WILL COUNTY, ILLINOIS

PURCHASING DEPARTMENT

JENNIFER BERTINO-TARRANT
WILL COUNTY EXECUTIVE

KEVIN LYNN
DIRECTOR

P. 815-740-4712
F. 815-740-4604
E. klynn@willcounty.gov

County Office Building
302 N. Chicago Street
Joliet, IL 60432

2024-77 Access Control Upgrade at 57 N Ottawa

Addendum #2 – August 7, 2024

We received the following questions regarding this RFQ:

Question #1: Can you tell us the name and version of the software?

Answer #1: 3xLogic and Version 6.7.10708.0

Question #2: Do you have an on-premise or cloud-based system?

Answer #2: On-Premise only

Question #3: Do you require standard HID proximity or I-Class readers?

Answer #3: Standard HID proximity

Question #4: Is the County providing open POE switch ports for each door controller?

Answer #4: We will provide power as long as they are ran to the current/closest closet that already has power

Question #5: The fire alarm company normally makes the final connection for the door release, where do you want us to provide our connection point?

Answer #5: Provide connection to outside of controller